

achieve outstanding client success



# Engineering a sustainable future

Geothermal Developments Realised

## Geothermal Potential in Great Britain and Northern Ireland

In cooperation with Ove Arup and Partners

September 2011

# Overview

- Introducing – SKM
- Scope/purpose of study
- UK resource review
- Reporting codes / Stored Heat Assessment
- Current projects in the UK
- Conceptual Projects / financial evaluation
- Geothermal policy support
- Possible development scenarios

# Sinclair Knight Merz Group

- A global engineering, sciences and project delivery firm
- Independent, employee-owned and values-driven
- Established in 1964 in Sydney, with UK offices since 1996
- 58 offices across Asia, Australia, Europe, Middle East, Africa, New Zealand and South America
- 6,500 people globally (700 in Europe)
- Revenue in excess of £650 million (A\$1 billion)
- Over 40 years global geothermal energy experience, SKM has been directly involved in developing 3,000 MW of geothermal generation
- Experience covers over 100 resources in 20 countries representing more than 50% of installed generating capacity

# Purpose of Study

## Background:

- 2020 UK renewable target of 15% energy from renewable sources – 12% of heat and 30% of electricity
- 2010 UK energy production from renewables was 3.3% - 1.8% of heat and 7.4% of electricity
- Renewable Heat Incentive introduced 2011
- Renewable Obligation banding review brought forward to 2011

## Purpose

- To review the geothermal potential in Great Britain and Northern Ireland for heat and power
- Evaluate the support mechanisms that may be required for geothermal to contribute to renewable targets

# Scope of Study

Focus on deep geothermal resources 500m to 5,000m  
Two geological settings for commercial development in the UK


## Pros:

- Naturally permeable
- Existing reservoir
- Commercially proven


## Contras:

- Lower temp
  - > 100°C power
  - > 60°C direct heat
  - > 40°C heat pump
- Higher power plant costs
- Lower power density

## Hydrothermal – Hot Sedimentary Aquifers



## Petrothermal – Engineered Geothermal Systems



## Pros:

- Higher temperatures
- Lower power plant costs
- Higher power density

## Contras:


- Reservoir has to be engineered
- Higher drilling costs (deeper)
- Distant to load centres

Image source courtesy of PANAX Geothermal Ltd.

# Hydrothermal

- Potential and existing geothermal resources in the UK based on current publicly available information

Location	Area (km <sup>2</sup> )	Reservoir Temp. (°C)	Depth of Base (m)	Thickness (m)
Wessex	3.5	108	3,000	200-500
Cheshire	33	115	4,500	200-1,200
East England	850	50	500	
Worcester	200	45	1,900	900
Northern Ireland (Larne)	22.5	83	1,600	300-600




Deep sedimentary basins and major radiogenic granites in the UK (Hurter & Haenel 2002)

# Petrothermal

- Background 52 mW/m<sup>2</sup>, 21°C/km
- Cornubian batholith in SW Cornwall
- Caledonian granites in the Lake District and Weardale
- East Grampian batholiths of Scotland

	Heat flow (mW/m <sup>2</sup> )	Temp gradient (°C/km)	Inferred area (km <sup>2</sup> )
<b>Cornwall</b>	110	35	1,500
<b>Weardale</b>	115	38	1,500
<b>Lake District</b>	73-119	34**	153
<b>Eastern Scotland</b>	59-76	17**	1,635


\*\* Temperature gradients are based on estimates only with no firm data available at depths greater than 300m



Heat flow map of the UK (Busby 2010)

# Reporting Codes

- Stored heat calculations are used to infer a geothermal resource
- Codes promote transparency, consistency and confidence in categorising geothermal resources and reserves
- UK Geothermal prospects fit mostly within the inferred category with limited information available to assess the viability
- Key 'Modifying Factors' detailed in the Australian code are needed to assess the prospects further



**Relationship between Exploration Results, Geothermal Resources and Geothermal Reserves (Source Australian Reporting Code 2008).**



# UK Resource Review – Stored Heat

- Assumes 17.5% recovery for hydrothermal and 2% for petrothermal
- Assumes 25 year life and binary plant for generation

Type	Location	Area (km <sup>2</sup> )	Reservoir Temp. (°C)	Base Temp. (°C)	Stored heat (PJ)	Generation Potential (MW <sub>e</sub> )	Heat Potential (MW <sub>th</sub> )
Hydrothermal Medium	Cheshire	33	115	70	1,500	38	370
Hydrothermal Medium	Wessex	3.5	108	70	137	3	30
Hydrothermal Low	East England	850	50	25	16,300	N/A	4,000
Hydrothermal Low	Worcester	200	45	25	11,100	N/A	2,700
Hydrothermal Low	Northern Ireland (Larne)	22.5	83	45	2,060	N/A	510
Petrothermal	Cornwall SW	90	190	70	14,700	54	410
Petrothermal	Lake District	1,500	160	70	182,000	620	5,100

# Current UK Projects and Technology

## Hydrothermal Projects – Hot Sedimentary Aquifers (HSA)

Developer, Location	Construction Date	Depth (m)	Temp. (°C)
Cofely, Southampton	1987	1,800	76
Keel University, Staffordshire	2012?	1,200	
Science Central, Newcastle	2011	2,000	
GT Energy, Manchester			
GT Energy, Ballymena			

## Petrothermal – Enhanced Geothermal System (EGS)

Developer, Location	Construction Date	Depth (m)	Temp. (°C)
Camborne School of Mines, Rosemanowes Quarry, near Redruth,	1976 - 1994	2,500 to 2,800	100
EGS Energy, Eden project, near St. Austell	2012?	4,000	
Geothermal Engineering, United Downs, near Redruth	2012	4,500	
Cluff Geothermal, Eastgate, Weardale	2004	995	45

# Conceptual Projects


- 18 possible UK 'concept' project cases were assumed involving 6 of the most likely resources
- CHP modelled as well as pure generation

Resource	Application Type	Gross capacity Elec. / Heat (MW)	Well Depth (m)	CAPEX (£ million)
Wessex	Hydrothermal CHP	0.75/5.5	2,500	14
Wessex	Hydrothermal CHP	1.5/11	2,500	27
Cheshire	Hydrothermal CHP	0.75/5.5	4,250	22
Cheshire	Hydrothermal CHP	1.5/11	4,250	43
Cornwall	Petrothermal CHP	10/21	5,000	115
Cornwall	Petrothermal CHP	5/11	5,000	59
Lake District	Petrothermal CHP	5/10	5,000	59
Cheshire	Hydrothermal Direct Heat	-/11.5	3,400	18
Wessex	Hydrothermal Direct Heat	-/10	3,000	16
Lough Neagh	Hydrothermal Direct Heat	-/5	2,000	10
Newcastle	Hydrothermal Heat Pump	-/4	1,500	8

# Financial Analysis - Results

- With the current available information and assumptions detailed in this study, the financial analysis suggests the following FiT and RHI tariffs as suitable:
- FiT levels for electrical and CHP projects
  - Approximately 300 £/MWh – equal to 5 ROC/MWh
- RHI levels for CHP and heat only projects
  - Retain existing RHI 30 £/MWh for CHP projects
  - Approximately 40 £/MWh for hydrothermal direct heat projects
  - Approximately 60 £/MWh for hydrothermal applications using a heat pump

# Geothermal Policy Support



Very few policies address the critical area of geothermal development – high cost/risk of up front exploration drilling

Level of support	UK	Europe Best
Electricity	130 £/MWh	220 £/MWh (Germany, Switzerland)
Heat	30 £/MWh	26 £/MWh (Germany)
Grant	£2 million	£4.3 million (Germany)

# Possible Development Scenarios

- Low – existing level of support
  - Electricity - 2 ROC per MWh (130 £/MWh)
  - Heat - 30 £/MWh
  - Grants of £1-2 million for drilling
- Medium - matching best available in Europe
  - Electricity - 4 ROC at ~ 220 £/MWh
  - Heat - 30 £/MWh
  - Grants of £6-8 million for drilling
- High
  - Electricity FiT of 400 €/MWh projects < 5 MW
  - 300 €/MWh projects < 5 MW
  - Heat – 40 £/MWh (33% uplift on the RHI for district heating)
  - Exploration risk mitigation
  - Drilling grants for pure heat projects
  - R&D funds
  - Specific geothermal licensing scheme

# Possible Development 2030 Results

- Low
  - Only existing projects are developed as demonstrations
  - 0.5-2% of potential
- Medium
  - Slow development of most attractive projects
  - 5-10% of potential
- High
  - Steady development of projects at all resources
  - 15-30% of potential

	Low Support Level (MW)	Medium Support Level (MW)	High Support Level (MW)
Electricity	15	60	240
Heat	70	540	2,200

achieve outstanding client success



# Engineering a sustainable future

Geothermal Developments Realised

## Geothermal Potential in Great Britain and Northern Ireland

In cooperation with Ove Arup and Partners

September 2011




# BACKUP



Engineering a sustainable future  
Geothermal Developments Realised

# Drilling Costs

Well costs



# Financial Analysis

- Feed in Tariffs (FiT) and Renewable Heat Incentive (RHI) evaluated
- Key assumptions:
  - Debt to equity ratio of 60:40 (80:20 scenario)
  - Cost of debt: 5% with loan term of 12 years
  - Cost of Equity at 20%
  - Capital grant - zero (£5 million scenario)
  - Project life of 25 years
  - Corporation Tax 25% with no capital allowances
  - Heating aspects used for 6 months of the year
  - FiT and RHI increased annually at inflation rate